



Carterton Source Water

The following table shows the mean values of chemical analysis of the water supply from the Kaipatangata Water Treatment Plant, compared with the maximum allowable value (MAV) acceptable range for each element as set out in the Drinking Water Standards New Zealand (DWSNZ).

Kaipatangata Stream

Date of Sample	Parameter	DWSNZ MAV (A) / GV (B)	Result
10/11/2023	Alkalinity - total CaCO ₃ /m ³	-	20
10/11/2023	Antimony - total g/m ³	0.1 (B)	<0.002
10/11/2023	Arsenic - total g/m ³	0.01 (A)	<0.001
0/01/1900	Boron - total g/m ³	1.4 (A)	0
10/11/2023	Barium - total g/m ³	-	0.009
10/11/2023	Cadmium - total g/m ³	0.004 (A)	<0.0002
27/09/2022	Calcium (Hardness) g/m ³	-	6.25
10/11/2023	Chloride g/m ³	250 (B)	8.17
10/11/2023	Chromium - total g/m ³	0.05 (A)	<0.001
13/06/2024	Conductivity at 25oC - mS/m	-	10.7
10/11/2023	Copper - total g/m ³	2 (A)	0.0008
21/02/2023	Carbon g/m ³		0.9
	Fluoride g/m ³		
7/06/2024	Iron - total g/m ³	0.2 (B)	<0.1
10/11/2023	Lead - total g/m ³	0.01 (A)	<0.0005
27/09/2022	Magnesium - total g/m ³	-	1.52
7/06/2024	Manganese - total g/m ³	0.04 (A)	<0.001
10/11/2023	Mercury - total g/m ³	0.007 (A)	<0.0005
10/11/2023	Nickel - total g/m ³	0.08 (A)	<0.0005
7/06/2024	Nitrate - nitrogen g/m ³	50 (A)	0.14
7/06/2024	pH	7.0 - 8.5 (B)	7.9
10/11/2023	Sodium - total g/m ³	-	6.12
10/11/2023	Sulphate g/m ³	250 (B)	2.67
7/06/2024	Colour (colour units)		1.9

The following table shows the mean values of chemical analysis of the water supply from the Frederick St Water Treatment Plant (highest value of 3 bores), compared with the maximum allowable value (MAV) acceptable range for each element as set out in the Drinking Water Standards New Zealand (DWSNZ).

Frederick Street Groundwater

Date of Sample	Parameter	DWSNZ MAV (A) / GV (B)	Result
10/11/2023	Alkalinity - total CaCO ₃ /m ³	-	33
10/11/2023	Antimony - total g/m ³	0.1 (B)	<0.002
30/06/2022	Arsenic - total g/m ³	0.01 (A)	<0.002
30/06/2022	Boron - total g/m ³	1.4 (A)	<0.05
10/11/2023	Barium - total g/m ³	-	0.02
30/06/2022	Cadmium - total g/m ³	0.004 (A)	<0.001
30/06/2022	Calcium (Hardness) g/m ³	-	7.8
10/11/2023	Chloride g/m ³	250 (B)	12



30/06/2022 Chromium - total g/m3	0.05 (A)	<0.001
13/06/2024 Conductivity at 25oC - mS/m	-	16.4
30/06/2022 Copper - total g/m3	2 (A)	<0.002
30/06/2022 Fluoride g/m3		0.15
7/06/2024 Iron - total g/m3	0.2 (B)	0.3
30/06/2022 Lead - total g/m3	0.01 (A)	0.001
30/06/2022 Magnesium - total g/m3	-	3.5
7/06/2024 Manganese - total g/m3	0.04 (A)	0.002
30/06/2022 Mercury - total g/m3	0.007 (A)	<0.001
30/06/2022 Nickel - total g/m3	0.08 (A)	0.004
7/06/2024 Nitrate - nitrogen g/m3	50 (A)	3.78
7/06/2024 pH	7.0 - 8.5 (B)	7.9
30/06/2022 Sodium - total g/m3	-	14.4
10/11/2023 Sulphate g/m3	250 (B)	9.71
7/06/2024 Colour (colour units)		0.1